

**APPENDIX A – EMPS ST. THOMAS
WATER QUALITY SUMMARY 2021**

MONTH	POST TREATMENT
	Free Cl ₂ mg/L
January	
Minimum	0.97
Maximum	2.10
Average	1.15
February	
Minimum	0.90
Maximum	1.86
Average	1.37
March	
Minimum	0.85
Maximum	2.57
Average	1.42
April	
Minimum	0.94
Maximum	2.42
Average	1.51
May	
Minimum	0.88
Maximum	2.11
Average	1.40
June	
Minimum	0.83
Maximum	2.77
Average	1.54
July	
Minimum	0.86
Maximum	2.57
Average	1.64
August	
Minimum	0.83
Maximum	2.51
Average	1.58
September	
Minimum	0.55
Maximum	2.78
Average	1.52
October	
Minimum	0.77
Maximum	3.15
Average	1.64
November	
Minimum	0.88
Maximum	2.96
Average	1.85
December	
Minimum	0.96
Maximum	2.87
Average	1.70
Yearly Minimum	0.55
Yearly Maximum	3.15
Yearly Average	1.53

Note: Chlorine residuals obtained from SCADA.